



BEELE Engineering bv/CSD International bv
Att.: Hans Beele
Beunkdijk 11
7122 NZ AALTEN
NETHERLANDS

DET NORSKE VERITAS AS
Approval Ship and Offshore
Fire Safety and Life-Saving
P.O.Box 300
1322 Høvik
Norway
Tel: +47 67 57 99 00
Fax: +47 67 57 99 11
<http://www.dnv.com>
Org. No: NO 945 748 931 MVA

Your ref.:

Our ref.:
TNANO844/AUB/344.1-001477-J-24

Date:
2013-06-06


BEELE ENGINEERING - Use of 22/15 sleeves instead of 18/12 & 27/19 sleeves


This is to confirm that Det Norske Veritas AS accept the use of the filler sleeve 22/15 instead of the combination of filler sleeves 18/12 and 27/19 in all Type Approved and MED certified penetration systems issued by Det Norske Veritas AS to Beele Engineering bv/CSD International bv, where NOFIRNO filler sleeves are used.

The statement is based on:

Fire test report No. 1302.106 dated 15 February 2013 from Beele Engineering and
Assessment No. 20130325/HN dated March 2013 issued by Kiwa Rechnology B.V., The Netherlands.

Yours faithfully
for DET NORSKE VERITAS AS


Petter Langnes
Head of Section
Fire Safety and Life-Saving


Patrick Aubert
Principal Surveyor